

**19th NATIONAL CERTIFICATION EXAMINATION
FOR
ENERGY MANAGERS & ENERGY AUDITORS – SEPTEMBER, 2018
PAPER – 2: ENERGY EFFICIENCY IN THERMAL UTILITIES**

Section – I: OBJECTIVE TYPE**Marks: 50 x 1 = 50**

- (i) Answer all **50** questions
(ii) Each question carries **One** mark
(iii) Please hatch the appropriate oval in the OMR answer sheet with **HB pencil only**, as per instructions

1.	Radiation losses from the surface of a boiler practically a) Are dependent on boiler loading b) Decrease with increase in boiler loading c) Are independent of boiler loading d) Increase with increase in boiler loading
2.	Desirable boiler water pH should be ? a) None of the below b) 7 - 9 c) 9 - 11 d) 5 - 7
3.	Soot deposition on boiler tubes is due to a) Incomplete combustion b) High moisture content in fuel c) High excess air d) Poor water treatment
4.	If 10 % air is entrained in a steam system at 5 kg/cm ² g then the saturation temperature of steam will be a) Equal to the saturation temperature at 5.5 kg/cm ² g b) More than the saturation temperature at 5 kg/cm ² g c) Equal to the saturation temperature at 5 kg/cm ² g d) Less than the saturation temperature at 5 kg/cm²g
5.	In a pressure reduction valve, which of these does not change ? a) Enthalpy b) Pressure c) Velocity d) Temperature
6.	Steam at 6 bar has a sensible heat of 159.33 kcal/kg and latent heat of 498.59 kcal/kg. If the steam is 95 % dry then the total enthalpy is a) 633 kCal/kg b) 649.95 kCal/kg c) 553 kCal/kg d) 625 kCal/kg

7.	Select the wrong statement with respect to steam traps a) <u>Does not allow condensate to escape</u> b) Does not allow steam to escape c) Capable of discharging air and other incondensable gases d) Discharges condensate as soon as it is formed
8.	Velocity of steam in steam pipe is directly proportional to _____ a) Diameter of the pipe b) <u>Specific volume of steam</u> c) Length of pipe d) Number of bends in pipe
9.	In a typical industrial steam distribution, the commonly used trap for main steam pipe lines is a) Open bucket trap b) Inverted bucket trap c) <u>Thermodynamic trap</u> d) Thermostatic trap
10.	For same inlet conditions of the steam, which of the following will generate the maximum mechanical power ? a) Extraction-cum-back pressure turbine b) Back pressure turbine c) Extraction-cum-condensing turbine d) <u>Condensing turbine</u>
11.	In an oil fired heat treatment furnace, which of the following is not required to determine its efficiency by direct method ? a) Calorific value of fuel b) <u>Oxygen percentage in flue gas</u> c) Fuel consumption d) Weight of input material
12.	In a coke fired cupola, carbon monoxide is produced in the a) Melting zone b) <u>Reducing zone</u> c) Combustion zone d) Preheating zone
13.	Tuyeres is a part of the equipment associated with a) <u>Cupola</u> b) Re-heating furnace c) Electrical melting arc furnace d) Induction furnace
14.	An increase in bulk density of a refractory increases its a) <u>All of the below</u> b) Heat capacity c) Resistance to slag penetration d) Thermal conductivity
15.	The storage heat losses in a batch type furnace can be best reduced by a) High silica brick b) <u>Ceramic fibre</u> c) High alumina brick d) Fire Clay brick
16.	Emissivity is a measure of material's ability to a) None of the below b) Only radiate heat c) <u>Absorb and radiate heat</u> d) Only absorb heat

17.	Which of the following depends on physical properties of fluids as well as geometry of the heat exchanger ? a) Effectiveness b) Fouling coefficient c) LMTD d) Overall heat transfer coefficient
18.	The waste heat boiler application is not suitable for which of the following? a) Hot air dryers b) Diesel engine c) Oil fired furnaces d) Gas turbine
19.	Moisture content in coal a) All of the below b) Helps in binding fines c) Aids in radiation heat transfer d) Increases heat loss due to evaporation and superheating of water vapour
20.	With respect to properties of steam a) The specific volume decreases as the pressure increases b) The latent heat increases as the pressure increases c) The specific volume increases as the pressure increases d) The sensible heat decreases as the pressure increases
21.	Oxidation of carbon to CO ₂ yields 8084 kcal/kg of carbon. Oxidation of carbon to CO in the flue gas yields 2430 kcal/kg of carbon. Oxidation of CO to CO ₂ will yield a) 540 kCal b) 5800 kCal c) 5464 kCal d) 5654 kCal
22.	The maximum loss that takes place in a fully condensing steam turbine power plant is a) Condenser losses b) Steam distribution loss c) Radiation and insulation loss d) Flue gas loss
23.	The difference between mean solid and mean gas velocity in FBC boiler is called a) Terminal velocity b) Slip velocity c) Settling velocity d) Fluidization factor
24.	Density of liquid fuel is measured by an instrument called a) All the below b) Hydrometer c) Luxmeter d) Anemometer
25.	The measured O ₂ in flue gas is 5.5 % by volume, the excess air percentage will be a) None of the below b) 55.9 % c) 35.5 % d) 41 %
26.	The efficiency of a reheating furnace, operating at 10 tonnes per hour consuming furnace oil of 230 kg/hour for reheating the material from 40 °C to 1100 °C (consider specific heat of material is 0.13 kCal / kg °C and calorific value of furnace oil is 10,000 kCal/kg) is _____. a) None of the below b) 70 %

36.	Which of the following increases, when high pressure steam is discharged to atmosphere? a) Specific volume c) Saturation temperature	b) Total enthalpy of steam d) Sensible heat
37.	Removal of condensate from main steam line is done to prevent a) All of the below c) Water hammer	b) Air locking d) Steam locking
38.	For flash steam calculation, flash steam quantity available depends upon a) Total heat of flash steam b) Steam pressure c) Steam enthalpy at atmospheric pressure d) Condensate pressure and flash steam pressure	
39.	Air venting in a steam system is required because air is _____. a) Diluent c) Inert	b) An insulator d) A good conductor
40.	Furnace wall heat loss does not depend on a) Material of stock to be heated c) Thermal conductivity of wall brick	b) Velocity of air around the furnace d) Temperatures of external wall surfaces
41.	In a CFBC boiler _____ are required to capture large recycled amount of bed material a) Scrubbers c) Bag filters	b) Mechanical cyclones d) Settling chambers
42.	Example for basic type of refractory is a) All the below c) Alumina	b) Chrome magnesite d) Chrome
43.	Which material is used to control SO ₂ emissions in FBC boilers a) Sand c) Silica	b) Lime stone d) CaO
44.	The effectiveness of a heat exchanger does not depend on a) LMTD c) Inlet temperature of hot fluid	b) Specific heat of cold fluid d) Specific heat of hot fluid
45.	Which of the following fuel needs maximum amount of excess air for complete combustion? a) Wood c) Pulverised coal	b) Natural gas d) Furnace oil

46.	In a coal fired boiler, which parameter influences flame profile the most? a) All of the below c) Hydrogen b) <u>Volatile matter</u> d) Fixed carbon
47.	Which one of the following boilers utilizes the combination of suspension and grate firing? a) Pulverized fuel boiler c) Traveling grate stoker boiler b) Fluidized bed boiler d) <u>Spreader stoker boiler</u>
48.	In an oil fired steam boiler the Air to Fuel ratio by mass is 15:1 & evaporation ratio is 14:1. The flue gas to fuel ratio will be a) 15 : 1 c) 1 : 1 b) <u>16 : 1</u> d) 29 : 1
49.	The maximum possible evaporation ratio of a boiler (From & At 100 °C basis) fired with coal having a calorific value of 4050 kcal/kg and operating at 80 % efficiency will be a) 9.4 c) 7.5 b) <u>6</u> d) 5
50.	When solutions of differing concentrations are separated by a semi-permeable membrane, water from less concentrated solution passes through the membrane to dilute the liquid of high concentration. This is called a) <u>Osmosis</u> c) Softening b) Ion exchange d) Reverse osmosis

..... **End of Section - I**

Section - II: SHORT DESCRIPTIVE QUESTIONS

Marks: 8 x 5 = 40

- (i) Answer all **Eight** questions
- (ii) Each question carries **Five** marks

S1	<p>A continuous process industry is operating with a 2 MW DG Set with 80 % load to meet the power requirements of the plant. The specific fuel consumption of the DG set is 4 kWh/liter. On energy auditor's suggestion, a waste heat recovery boiler was installed to recover heat from exhaust gas and generating 800 kg/hr of saturated steam at 10 kg/cm².</p> <p>The waste heat recovery boiler operating data are given below.</p> <ul style="list-style-type: none"> • Feed water temperature = 60 °C • Enthalpy of steam at 10 kg/cm² = 660 kCal/kg • Specific gravity of diesel = 0.85 • GCV of diesel = 10500 kCal/kg <p>Calculate the following. (each carries 2.5 Marks)</p>
----	---

	<p>a) Efficiency of DG set before waste heat recovery boiler installation</p> <p>b) Cogeneration system efficiency after waste heat recovery boiler installation</p>
Ans	<p>Diesel consumption Litre / hour</p> $= ((2 \times 1000) \times 0.8) / 4 = 400 \text{ litre / hour}$ <p>a) DG set efficiency</p> $= \frac{2000 \text{ kW} \times 0.8 \text{ loading} \times 860 \text{ kcal/kWh} \times 100}{400 \text{ lit/h} \times 0.85 \text{ kg/lit} \times 10500 \text{ kcal/kg}} = 38.54 \%$ <p>b) Co-gen System Efficiency after WHR boiler installation =</p> $\frac{[(2000 \text{ kW} \times 0.8 \text{ loading} \times 860 \text{ kcal/hr/kW}) + (800 \text{ kg steam /hr} \times (660-60) \text{ kcal/kg})] \times 100}{[400 \text{ lit} \times 0.85 \text{ kg/lit} \times 10500 \text{ kcal/kg}]}$ <p>= 52%</p>
S2	<p>In a process plant 200 kg/hr of hot condensate at 6 bar(g) having a sensible heat of 166 kCal/kg is discharged. The plant also requires low pressure steam at a pressure of 1 bar(g) for heating application. Find out the quantity of flash steam generated in the flash vessel in kg/hr. The condensate at a pressure of 1 bar(g) has a sensible heat of 120 kCal/ kg and a latent heat of 526 kCal/kg.</p>
Ans	$\text{Flash steam available \%} = \frac{S_1 - S_2}{L_2} \times 100$ <p>Where,</p> <p>S₁ = is the sensible heat of higher pressure steam</p> <p>S₂ = is the sensible heat of steam at lower pressure</p> <p>L₂ = is the latent heat of flash steam at lower pressure</p> $\text{Flash steam generated} = \left(\frac{166 - 120}{526} \right) \times 200 \text{ Kg/hr} = 17.49 \text{ kg/hr}$
S3	<p>A coal fired thermic fluid heater is used to supply heat to a dryer. The hot oil circulation is supplied at 270 oC, with a flow of 100 m³/hr and operating with temperature difference of 20 oC. Estimate the coal requirement if the thermal efficiency of the heater is 65 % and GCV of the coal is 4200 kCal/hr. Consider specific heat & density of the thermic fluid to be 0.55 kcal/kg oC & 820 kg/m³ respectively.</p>
Ans	<p>Absorbed heat in thermic fluid = m * Cp * Δ T</p> $= (100 \times 820) \times 0.55 \times 20$ <p>= 902000 kcal/hr</p> <p>Thermal efficiency of the heater = absorbed duty / input heat duty</p> <p>Mass of coal required = absorbed duty / (efficiency * calorific value of coal)</p> $= 902000 / (0.65 \times 4200)$ <p>= 330.4 kg/hr</p>

S4	Write short notes on wet and dry methods of preservation of boiler.
Ans	Refer Guide Book -2, Chapter 2, Page 54 and 55
S5	Calculate the reduction in pressure drop in meters when pipe diameter is increased from 250 mm to 350 mm for a length of 500 meters. The water velocity is 2 m/s in the 250 mm diameter pipe, and friction factor is 0.005.
Ans	<p>Pressure drop = $4fLV^2 / 2gD$</p> <p>Pressure drop with 250 mm = $(4 \times 0.005 \times 500 \times 2^2) / (2 \times 9.81 \times 0.250)$ $= 8.155 \text{ m}$</p> <p>Velocity of water in pipe of 350 mm diameter $= (0.25 \times 0.25 \times 2) / (0.35 \times 0.35) = 1.02 \text{ m/s}$</p> <p>Pressure drop with 350 mm = $(4 \times 0.005 \times 500 \times 1.02^2) / (2 \times 9.81 \times 0.350)$ $= 1.515 \text{ m}$</p> <p>Pressure drop reduction = $8.155 - 1.515 = \mathbf{6.64 \text{ m}}$</p>
S6	A counter flow double pipe heat exchanger using hot process liquid is used to heat water which flows at 20 m ³ /hr. The process liquid enters the heat exchanger at 180 °C and leaves at 130 °C. The inlet and exit temperatures of water are 30 °C and 90 °C. Specific heat of water is 4.187 kJ/kg K. Calculate the heat transfer area if overall heat transfer coefficient is 820 W/m ² K. What would be the percentage increase in the area if fluid flow were parallel assuming same overall heat transfer coefficient?
Ans	<p>Counter Flow</p> <ul style="list-style-type: none"> ▪ Water inlet temperature 30 °C ▪ Water outlet temperature 90 °C ▪ Flow rate of water 20 m³/hr ▪ Heat content in water = $20000 \times (90 - 30) \times 4.187 = 5024400 \text{ kJ/hr} = 1395.6 \text{ kW}$ ▪ Process fluid inlet temperature = 180 °C ▪ Process fluid outlet temperature = 130 °C ▪ $\Delta T_1 = 180 - 90 = 90^\circ\text{C}$, $\Delta T_2 = 130 - 30 = 100^\circ\text{C}$ ▪ $T_{LMTD} = (\Delta T_1 - \Delta T_2) / (\ln(\Delta T_1 / \Delta T_2)) = 10 / \ln(100/90) = \mathbf{94.91 \text{ }^\circ\text{C}}$ ▪ $U = 820 \text{ W/m}^2\text{K}$ ▪ $Q = UAT_{LMTD}$ ▪ $A = 1395.6 \times 1000 / (94.91 \times 820) = 17.9 \text{ m}^2$ <p>Parallel flow:</p> <ul style="list-style-type: none"> ▪ $\Delta T_1 = 180 - 30 = 150^\circ\text{C}$, $\Delta T_2 = 130 - 90 = 40^\circ\text{C}$ ▪ $T_{LMTD} = (\Delta T_1 - \Delta T_2) / (\ln(\Delta T_1 / \Delta T_2)) = 110 / \ln(150/40) = \mathbf{83.2 \text{ }^\circ\text{C}}$ ▪ $U = 820 \text{ W/m}^2\text{K}$ ▪ $Q = UAT_{LMTD}$ ▪ $A = 1395.6 \times 1000 / (83.2 \times 820) = 20.45 \text{ m}^2$ <p>% Increase in area = $((20.45 - 17.9) / 17.9) \times 100 = 14.24 \text{ \% increase}$</p>
S7	Explain the phenomenon of water hammer in steam system and how it can be eliminated?
Ans	Refer Guide Book -2, Chapter 3, Page 91

S8	<p>In a heat exchanger, steam is used to heat 3000 litres/hr of furnace oil from 30 °C to 100 °C. The specific heat of furnace oil is 0.22 kCal/ kg/°C and the density of furnace oil is 0.95. How much steam per hour is needed if steam at 4 kg/cm² with latent heat of 510 kCal/kg is used?</p> <p>If steam cost is Rs.4/kg and electrical energy cost is Rs.8/kWh, which type of heating would be more economical in this particular case? (assume no losses in electrical and steam heating process)</p>
Ans	<p>Total heat required = $m C_p \Delta T$</p> <p style="padding-left: 40px;">= $(3000 \times 0.95) \times 0.22 \times (100-30)$</p> <p style="padding-left: 40px;">= 43890 kcal/hr</p> <p>a) Amount of steam required = $43890/510$</p> <p style="padding-left: 40px;">= 86 kg/hr</p> <p style="padding-left: 40px;">Steam cost = $86 \times \text{Rs.}4$</p> <p style="padding-left: 40px;">= Rs. 344/hr</p> <p>b) Amount of electricity required = $43890/860$</p> <p style="padding-left: 40px;">= 51 kWh</p> <p style="padding-left: 40px;">= $51 \times \text{Rs.} 8$</p> <p style="padding-left: 40px;">= Rs.408/ hr</p> <p>Answer : Steam heating will be more economical</p>

..... End of Section - II

Section - III: LONG DESCRIPTIVE QUESTIONS

Marks: 6 x 10 = 60

- (i) Answer all **Six** questions
- (ii) Each question carries **Ten** marks

L1	<p>An air preheater in a 90 TPH induced draft boiler was showing the following readings:</p> <ul style="list-style-type: none"> i. Flue gas inlet temperature: 319.5 °C ii. Flue gas Outlet temperature: 160 °C iii. Air inlet temperature: 70 °C iv. Air outlet temperature: 210 °C <p>The steam to fuel ratio is 12 and air to fuel ratio is 14. It was found that there was air ingress from atmosphere to flue gas side. Ambient air temperature was 30 °C. Assuming that the specific heat capacity of air and flue gas to be the same at 0.24 kcal/kg K and the amount of heat picked up by fresh air remains the same.</p> <p>Calculate the following : (each carries 5 Marks)</p> <ul style="list-style-type: none"> a) The amount of air ingress into the flue gas path. b) The flue gas temperature after air preheater in case of no air leak to flue gas
----	---

	circuit.
Ans	<p>a. Steam flow: 90TPH Steam to fuel ratio: 12 → fuel consumed is 7.5 TPH Air to fuel ratio: 14 → air used in boiler is 105 TPH Flue gas = Air + Fuel → Flue gas = 105+7.5 = 112.5 TPH</p> <p>Air ingress is at 30 deg C. Making an energy balance around APH: we get $112.5 * 319.5 + 105 * 70 + x * 30 = 105 * 210 + (112.5+x) * 160$ Solving for x, we get air ingress to be 25 TPH</p> <p>Flue Gas Temperature b. → $112.5 * 319.5 + 105 * 70 = 105 * 210 + 112.5 * T$</p> <p>Solving for T, we get the corrected flue gas temperature to be 189 °C</p>
L2	<p>In a leather industry, a leather drier requires 80 m³/min of air at 92 °C, which is heated by wood fired thermic fluid heater. The density of air is 1.2 kg/m³ and specific heat of air is 0.24 kcal/kg °C. The inlet air temperature to the drier is 32 °C and the drier is operating for 8 hrs per day.</p> <p>The efficiency of the wood fired heater and its distribution piping system is 50 %. The gross calorific value and the cost of purchased wood are 2000 kCal/kg and Rs. 5000 per ton. The auxiliary power consumption for operating the thermic fluid heater is 10 kW.</p> <p>The energy auditor recommended replacing the existing drying system with a 40 kW infrared electric heater drier. The kW loading of the proposed drier will be 70 % over an 8 hour plant operating period. The investment for the new drier is Rs. 10 Lakhs.</p> <p>If the cost of electricity is Rs. 7/kWh, calculate the following:</p> <p>a) Find out the annual energy cost savings of replacement of thermic fluid system with infra-red heater? (7 Marks)</p> <p>b) Find out the payback period. (3 Marks)</p>
Ans	<p>Cost of wood fired thermic fluid heater operation</p> <p>Air flow rate (vol) = 80 m³/min x 60 = 4800 m³/hr Air flow rate (mass) = 4800 x 1.2 = 5760 kg/hr Sensible heat of air = m x Cp x T = 5760 x 0.24 x (92-32) = 82944 kcal/hr</p> <p>Efficiency of wood fired heater =50% Wood consumption = 82944/ (2000 x0.5) per hr=83 kg per day Cost of wood per day = 83 x Rs 5 x 8 hour = Rs 3320 per day Cost of Auxiliary electricity = 10 kW x 8 hrs x 7 = Rs.560 Total cost of operation = 3880 Rs.</p> <p>Cost of Infra-red heater operation</p> <p>Electric heater rating= 40 kw Electricity consumption per day= 40 kw x 0.7 x8hr = 224 kwh per day</p>

	<p style="text-align: right;">$= 224 \times \text{Rs } 7 = \text{Rs } 1568 \text{ per day}$</p> <p>Cost saving potential = $3880 - 1568 = \text{Rs } 2312$</p> <p>Annual saving potential = $2312 \times 300 \text{ days} = \text{Rs. } 6.94 \text{ lakhs}$</p> <p>Investment = 10 lakhs</p> <p>Payback period = $10 / 6.94 = 17 \text{ months or } 1.4 \text{ years}$</p> <p>Or</p> <p>Annual saving potential = $2312 \times 365 \text{ days} = \text{Rs. } 8.44 \text{ lakhs}$</p> <p>Investment = 10 lakhs</p> <p>Payback period = $10 / 8.44 = 14 \text{ months or } 1.2 \text{ years}$</p>																												
<p>L3</p>	<p>As a part of energy conservation measure, APH (Air Pre-heater) is installed in a forced draft furnace. The APH is designed to pre-heat $240 \text{ m}^3/\text{min}$ of combustion air to $250 \text{ }^\circ\text{C}$. Flue gas enters the APH at $375 \text{ }^\circ\text{C}$. Calculate the flue gas quantity leaving the stack and also determine the improvement in furnace efficiency after the installation of APH with the following data,</p> <table style="margin-left: 40px;"> <tr> <td>Density of air</td> <td>: 1.15 kg/m^3</td> </tr> <tr> <td>Specific heat of air</td> <td>: $0.24 \text{ kCal/kg } ^\circ\text{C}$</td> </tr> <tr> <td>Specific heat of flue gas</td> <td>: $0.2 \text{ kCal/kg } ^\circ\text{C}$</td> </tr> <tr> <td>Amount of fuel fired</td> <td>: 920 kg/hr</td> </tr> <tr> <td>Calorific value of fuel</td> <td>: 9850 kCal/kg</td> </tr> <tr> <td>Air to fuel ratio</td> <td>: 18</td> </tr> <tr> <td>Efficiency of furnace</td> <td>: 80%</td> </tr> <tr> <td>Ambient temperature</td> <td>: $30 \text{ }^\circ\text{C}$</td> </tr> </table>	Density of air	: 1.15 kg/m^3	Specific heat of air	: $0.24 \text{ kCal/kg } ^\circ\text{C}$	Specific heat of flue gas	: $0.2 \text{ kCal/kg } ^\circ\text{C}$	Amount of fuel fired	: 920 kg/hr	Calorific value of fuel	: 9850 kCal/kg	Air to fuel ratio	: 18	Efficiency of furnace	: 80%	Ambient temperature	: $30 \text{ }^\circ\text{C}$												
Density of air	: 1.15 kg/m^3																												
Specific heat of air	: $0.24 \text{ kCal/kg } ^\circ\text{C}$																												
Specific heat of flue gas	: $0.2 \text{ kCal/kg } ^\circ\text{C}$																												
Amount of fuel fired	: 920 kg/hr																												
Calorific value of fuel	: 9850 kCal/kg																												
Air to fuel ratio	: 18																												
Efficiency of furnace	: 80%																												
Ambient temperature	: $30 \text{ }^\circ\text{C}$																												
<p>Ans</p>	<p>Solution:</p> <table style="margin-left: 40px;"> <tr> <td>Amount of Air flow</td> <td>$= 240 \times 60 \times 1.15$</td> </tr> <tr> <td></td> <td>$= 16560 \text{ kg/hr}$</td> </tr> <tr> <td>Amount of fuel</td> <td>$= 16560 / 18$</td> </tr> <tr> <td></td> <td>$= 920 \text{ kg/hr}$</td> </tr> <tr> <td>Amount of flue gas</td> <td>$= 16560 + 920$</td> </tr> <tr> <td></td> <td>$= 17480 \text{ kg/hr}$</td> </tr> <tr> <td>Heat gain by combustion air</td> <td>$= 16560 \times 0.24 \times (250 - 30)$</td> </tr> <tr> <td></td> <td>$= 874368 \text{ Kcal/hr}$</td> </tr> <tr> <td>Temperature difference in flue gas</td> <td>$= 874368 / (17480 \times 0.2)$</td> </tr> <tr> <td></td> <td>$= 250 \text{ }^\circ\text{C}$</td> </tr> <tr> <td>Flue gas leaves the stack at temp</td> <td>$= 375 - 250 = 125 \text{ }^\circ\text{C}$</td> </tr> <tr> <td>Efficiency of APH</td> <td>$= \text{heat absorbed by air} / \text{Heat input} \times 100$</td> </tr> <tr> <td></td> <td>$= 874368 / (920 \times 9850) \times 100$</td> </tr> <tr> <td></td> <td>$= 9.6 \%$</td> </tr> </table>	Amount of Air flow	$= 240 \times 60 \times 1.15$		$= 16560 \text{ kg/hr}$	Amount of fuel	$= 16560 / 18$		$= 920 \text{ kg/hr}$	Amount of flue gas	$= 16560 + 920$		$= 17480 \text{ kg/hr}$	Heat gain by combustion air	$= 16560 \times 0.24 \times (250 - 30)$		$= 874368 \text{ Kcal/hr}$	Temperature difference in flue gas	$= 874368 / (17480 \times 0.2)$		$= 250 \text{ }^\circ\text{C}$	Flue gas leaves the stack at temp	$= 375 - 250 = 125 \text{ }^\circ\text{C}$	Efficiency of APH	$= \text{heat absorbed by air} / \text{Heat input} \times 100$		$= 874368 / (920 \times 9850) \times 100$		$= 9.6 \%$
Amount of Air flow	$= 240 \times 60 \times 1.15$																												
	$= 16560 \text{ kg/hr}$																												
Amount of fuel	$= 16560 / 18$																												
	$= 920 \text{ kg/hr}$																												
Amount of flue gas	$= 16560 + 920$																												
	$= 17480 \text{ kg/hr}$																												
Heat gain by combustion air	$= 16560 \times 0.24 \times (250 - 30)$																												
	$= 874368 \text{ Kcal/hr}$																												
Temperature difference in flue gas	$= 874368 / (17480 \times 0.2)$																												
	$= 250 \text{ }^\circ\text{C}$																												
Flue gas leaves the stack at temp	$= 375 - 250 = 125 \text{ }^\circ\text{C}$																												
Efficiency of APH	$= \text{heat absorbed by air} / \text{Heat input} \times 100$																												
	$= 874368 / (920 \times 9850) \times 100$																												
	$= 9.6 \%$																												

	Overall efficiency after APH = 80 + 9.6 % = 89.6 %
L4	<p>a) Write short notes on the following (each carries 2.5 Marks)</p> <ul style="list-style-type: none"> • Advantage of Micro turbine in Steam System • Trigeneneration with example <p>b) Why is individual trapping preferred over group trapping ? (5 Marks)</p>
Ans	<p>a)</p> <ul style="list-style-type: none"> • (Refer BEE Guide book 2, Chapter 7, Page No-209) • (Refer BEE Guide book 2, Chapter 7, Page No-208) <p>b) (Refer BEE Guide book 2, Chapter 7, Page No-208)</p>
L5	<p>Explain the following (each carries 5 Marks)</p> <ul style="list-style-type: none"> • Advantages of using ceramic fibre in furnaces • Advantages of using fluidized bed boilers
Ans	<ul style="list-style-type: none"> • (Refer BEE Guide book 2, Chapter 5, Page No:164-165) • (Refer BEE Guide book 2, Chapter 6, Page no: 182-183)
L6	<p>An oil fired Boiler is generating 100 TPH of steam at 85 % efficiency and operating 330 days in a year. The management has installed a water treatment plant with Rs. 2 Crore investment for reducing the Total Dissolved Solidas (TDS) in boiler feed from 450 ppm to 150 ppm. The maximum permissible limit of TDS in the boiler is 3000 ppm and make up water is 10 %. The temperature of blowdown water is 175 0C and the boiler feed water temperature is 45 0C. The calorific value of fuel oil is 10,200 kCal/kg. Calculate the payback period if the cost of fuel is Rs. 45,000 per ton.</p>
Ans	<p>Blow down % = $\frac{\text{Feed water TDS} * \% \text{ make up water} * 100}{(\text{maximum permissible TDS in boiler water} - \text{Feed water TDS})}$</p> <p>Initial blow down = 450 * 10 / (3000 – 450) Initial blow down = 1.764 % Improved blow down = 150 * 10 / (3000 – 150) Improved blow down = 0.526 % Reduction in blow down = 1.76 – 0.526 Reduction in blow down = 1.238 % Reduction in blow down = 1.238 * 100 * 1000 / 100 Reduction in blow down = 1238 kg/hr Specific heat of water is 1 kcal/kg°C Heat savings = m * Cp * (T₁ – T₂) = 1238 * 1 * (175 – 45) Heat savings = 160940 kcal/hr Fuel Oil saving = 160940 / (10200 * 0.85) = 18.6 kg/hr = 18.6 * 24 * 330 / 1000 = 147 MT / annum</p> <p>Fuel Oil – cost savings = 147* 45000 = Rs. 66 lakh</p> <p>Investment on water treatment plant = Rs. 2 Crore</p>

	Payback period	= $2 / 0.66$
	Payback period	= 3.0 years (or) 36 months

..... **End of Section - III**