

**19th NATIONAL CERTIFICATION EXAMINATION
FOR
ENERGY MANAGERS & ENERGY AUDITORS – SEPTEMBER, 2018**

PAPER – 1: GENERAL ASPECTS OF ENERGY MANAGEMENT & ENERGY AUDIT

Section – I: OBJECTIVE TYPE

Marks: 50 x 1 = 50

- (i) Answer all **50** questions
(ii) Each question carries **one** mark
(iii) Please hatch the appropriate oval in the OMR answer sheet with **HB pencil only**, as per instructions

1.	A waste heat recovery system requires Rs. 50 lakhs investment and Rs. 2 lakhs per year to operate and maintain. If the annual savings is Rs. 22 lakhs, the payback period will be <div style="display: flex; justify-content: space-around;"> a) 10 years b) 2.5 years </div> <div style="display: flex; justify-content: space-around;"> c) 3 years d) 2.28 years </div>
2.	What is the heat content of the 200 liters of water at 500 0C in terms of the basic unit of energy in Kilo Joules? <div style="display: flex; justify-content: space-around;"> a) 41870 b) 23880 </div> <div style="display: flex; justify-content: space-around;"> c) 10000 d) 30000 </div> <p>Note: 1 Mark is awarded to all candidate who have attempted this question.</p>
3.	Which of the following GHGs has the longest atmospheric life time? <div style="display: flex; justify-content: space-around;"> a) PFC b) SF₆ </div> <div style="display: flex; justify-content: space-around;"> c) CFC d) CH₄ </div>
4.	Which of the following is used for non-contact measurement of temperature? <div style="display: flex; justify-content: space-around;"> a) All of the below b) Infrared Thermometer </div> <div style="display: flex; justify-content: space-around;"> c) Leaf type contact probe d) Thermocouples </div>
5.	The force field analysis in energy action planning considers <div style="display: flex; justify-content: space-around;"> a) No forces b) Negative forces only </div> <div style="display: flex; justify-content: space-around;"> c) Both negative and positive forces d) Positive forces only </div>

6.	Which of the following equation is used to calculate the future value of the cash flow? a) $NPV / (1 + i)^n$ b) $NPV / (1 - i)^n$ c) <u>$NPV (1 + i)^n$</u> d) $NPV (1 - i)^n$
7.	For investment decision, ROI must always be ____ prevailing interest rate. a) No relation b) <u>Higher than</u> c) Equal to d) Lower than
8.	Large scattering on production versus energy consumption trend line indicates a) None of the below b) Inefficient equipment c) Inefficient process d) <u>Poor process control</u>
9.	Frequency of energy audit for designated consumers is ____ a) Once in five years b) Once in two years c) <u>Once in three years</u> d) Once in a year
10.	The rotor axis is aligned with the wind direction in a wind mill by ____ control a) All of the below b) Pitch c) Disc brake d) <u>Yaw</u>
11.	Producer gas basically comprises of a) Only CO and H ₂ b) Only CH ₄ c) CO and CH ₄ d) <u>CO, H₂ and CH₄</u>
12.	The lowest theoretical temperature to which water can be cooled in a cooling tower is a) <u>WBT of the atmospheric air</u> b) Average DBT and WBT of the atmospheric air c) DBT of the atmospheric air d) Difference between DBT and WBT of the atmospheric air
13.	In a solar thermal power station Molten salt is preferred as it provides an efficient low cost medium to store ____ energy a) Potential b) <u>Thermal</u> c) Kinetic d) Electrical

14.	From Voltage, Amps and Power factor given in the name plate of a motor, one can calculate _____. a) Both (b) & (c) b) Shaft power c) Rated input power d) Rated output power
15.	RPM of an electric motor is measured using _____. a) Rotameter b) Stroboscope c) Lux meter d) Ultrasonic meter
16.	If asset depreciation is considered, then net operating cash inflow would be a) None of the below b) Higher c) No effect d) Lower
17.	Which of the following comes under capital cost in a project? a) All of the below b) Installation cost c) Commissioning cost d) Design cost
18.	Energy consumption per GDP is termed as _____. a) All of the below b) Energy intensity c) Energy efficiency index d) Energy factor
19.	A three phase induction motor is drawing 10 Ampere at 440 Volts. If the operating power factor of the motor is 0.9 and the efficiency of the motor is 95 %, then the mechanical shaft power of the motor is a) 7.21 kW b) 4.18 kW c) 6.51 kW d) 3.76 kW
20.	For an activity in a project, Latest start time is 8 weeks and Latest finish time is 12 weeks. If the earliest finish time is 9 weeks, Slack time for the activity is _____. a) None of the below b) 4 weeks c) 1 week d) 3 weeks
21.	The amount of CO ₂ produced in complete combustion of 18 kg of carbon is _____. a) 792 b) 44 c) 66 d) 50

22.	Which mode of heat transfer does not require medium? a) Conduction b) Forced convection c) <u>Radiation</u> d) Natural convection
23.	If the fixed energy consumption of a company is 2000 kWh per month and the line slope of the energy (y) versus production (x) chart is 0.3, then the energy consumed in kWh per month for a production level of 60,000 tons/month is _____. a) <u>None of the below</u> b) 18,000 kWh c) 22,000 kWh d) 16,000 kWh
24.	Which technique takes care of time value of money in evaluation? a) <u>Both (b) & (c)</u> b) IRR c) NPV d) Payback period
25.	The heat rate of a power plant is expressed as a) kWh / kVA b) <u>kCal/kWh</u> c) kg of steam / kg of fuel d) kWh/kg of steam
26.	Which equipment does not come under mandatory labelling program? a) Distribution transformer b) Frost free refrigerator c) <u>Induction motors</u> d) Room Air conditioners
27.	Furling speed of wind turbine indicates ____ a) None of the below b) Cut in speed c) Rated speed d) <u>Cut out speed</u>
28.	One Silicon cell in a PV module typically produces a) 12 V b) 1 V c) 2 V d) <u>0.5 V</u>
29.	The input to a fuel cell is. a) All of the below b) <u>Hydrogen</u> c) Oxygen d) Electricity
30.	The production factor is defined as the ratio of a) Reference year production to the current year production b) Current year production to the reference month production c) Reference month production to the current month production d) <u>Current year production to the reference year production</u>

31.	To reduce the distribution losses within a plant, the capacitors should be located a) Before the billing meter b) Farthest from the load c) In the substation d) <u>Closest to the load</u>
32.	Absolute pressure is measured as a) None of the below b) Gauge pressure + Atmospheric pressure c) Gauge pressure/Atmospheric pressure d) Gauge pressure – Atmospheric pressure
33.	The dryness (x) fraction of superheated steam is taken as a) <u>x = 1</u> b) x = 0.9 c) x = 0.87 d) x = 0
34.	When the evaporation of water from a wet substance is zero, the relative humidity of the air is likely to be a) Unpredictable b) <u>100 %</u> c) 50 % d) 0 %
35.	Which of the following type of collector is used for low temperature systems? a) None of the below b) Line focusing parabolic collector c) Parabolic trough collector d) <u>Flat plate collector</u>
36.	Which among the following is not a renewable source of energy? a) Wind b) Rice husk c) <u>Nuclear</u> d) Bagasse
37.	What is shale Oil? a) Combustible brownish-black sedimentary rock b) Heavy black viscous oil combination of clay, sand, water and bitumen c) A form of naturally compressed peat d) <u>Sedimentary rock containing solid bituminous materials</u>
38.	Which of the following has the lowest energy content in terms of MJ/kg? a) Furnace oil b) Diesel c) <u>Bagasse</u> d) LPG
39.	_____ and _____ consume major share of Natural Gas consumption in India. a) Domestic Sector and Fertilizer Industries b) Transport sector and Fertilizer Industry c) <u>Power Generation and Fertilizer Industries</u>

	d) Domestic sector and Transport sector
40.	The sector consuming major share of energy in India is a) Domestic Sector b) Transport Sector c) <u>Industrial Sector</u> d) Agriculture Sector
41.	Which of the following designated consumer has the lowest energy intensity? a) Chlor alkali b) Iron and Steel c) Cement d) <u>Aluminium</u>
42.	Which of the following is not a Demand Side Management measure? a) Use of ice bank system b) <u>Maximizing fossil fuel based energy utilization</u> c) Replacement of inefficient electrical appliances d) Implementing Time of the Day (ToD) Electricity Tariff
43.	Which of the following does not meet the Designated Consumer criteria? a) Textile Industries with minimum annual energy consumption of 3000 toe. b) Cement Industries with minimum annual energy consumption of 30,000 toe. c) <u>Chlor-Alkali Industries with minimum annual energy consumption of 7500 toe.</u> d) Pulp and Paper Industries with minimum annual energy consumption of 30,000 toe.
44.	The kW or HP of a motor given on the name plate indicates a) The input power to the motor at any load b) <u>The shaft output of the motor at full load</u> c) The input power to the motor at the best efficiency point d) The shaft output of the motor at part load
45.	Which of the following has the highest Specific Heat? a) <u>Water</u> b) Aluminium c) Copper d) Steel
46.	Heat transfer in an air cooled condenser occurs predominantly by a) None of the below b) <u>Convection</u> c) Radiation d) Conduction

47.	<p>Definition of Energy Audit as per EC Act does not include:</p> <p>a) Action plan required for energy saving</p> <p>b) Evaluation of Techno-economics</p> <p>c) Verification, monitoring and analysis of energy use</p> <p>d) <u>Creation of an Energy Management System (EnMS)</u></p>
48.	<p>The ISO standard for Energy Management System is</p> <p>a) ISO 18001</p> <p>b) <u>ISO 50001</u></p> <p>c) ISO 9001</p> <p>d) ISO 14001</p>
49.	<p>To arrive at the relative humidity at a point we need to know_____of air</p> <p>a) <u>Both b & d</u></p> <p>b) Wet bulb temperature</p> <p>c) Enthalpy</p> <p>d) Dry bulb temperature</p>
50.	<p>As per Energy Conservation Act, 2001 appointment of BEE Certified Energy Manger is mandatory for</p> <p>a) All commercial buildings</p> <p>b) All large Industrial consumers</p> <p>c) <u>All designated consumers</u></p> <p>d) All State designated agencies</p>

..... **End of Section I**

Section – II: SHORT DESCRIPTIVE QUESTIONS

Marks: 8 x 5 = 40

- (i) Answer all **Eight** questions
- (ii) Each question carries **Five** marks

S-1	<p>A thermal power plant uses 0.72 kg of coal to generate one KWh of electricity. If the coal contains 38 % carbon by weight, calculate the amount of CO₂ emission/kWh under complete combustion.</p>
Ans	<p>Amount of carbon present in coal = $0.72 \times 38 / 100$ = 0.2736 kg</p> <p>As per chemical reaction, $C + O_2 = CO_2$ 1 kg of carbon generates 44/12 kg of carbon dioxide (CO₂) under complete combustion Amount of CO₂ generation while generating one KWh of electricity = $0.2736 \times 44 / 12$ = 1.0032 Kg/KWh</p>

S-2	A solar photovoltaic power plant is installed with 350 Watts panel of size 1.5 m x 1.5 m in a roof top area of a building having dimension of 9 m x 10 m. If solar insolation is 1,000 W/m ² , calculate the panel conversion efficiency?
Ans	Area of solar cell = 1.5 x 1.5 = 2.25 m ² Efficiency = (350 / (2.25 x 1000)) x 100 = 15.6 %
S-3	List any five equipment and appliances covered under Standards and Labelling program.
Ans	Refer BEE Guide Book 1- Page No 37
S-4	State true or false (each carries 1 Mark) a) When it is raining, there is a substantial difference between the dry and wet bulb temperatures b) The specific gravity of light diesel oil is given in kg/m ³ c) The major constituent of LNG is propane d) Evaporative cooling of space requires use of refrigerant R134a e) HSD needs preheating to increase viscosity
Ans	a) False b) False c) False d) False e) False
S-5	In a textile plant monthly energy consumption is 7,00,000 kWh of electricity, 40 kL of furnace oil (specific gravity = 0.92) for thermic fluid heater, 360 tonne of coal for steam boiler and 10 kL of HSD (specific gravity = 0.885) for material handling equipment. Compute the energy consumption in terms of Metric Tonne of Oil Equivalent(MTOE) for the plant. Given Data: (1 kWh = 860 kcal, GCV of coal = 3450 kCal/kg, GCV of furnace oil = 10,000 kcal/kg, GCV of HSD = 10,500 kcal/kg, GCV of rice husk = 3100 kcal/kg, 1 kg oil equivalent = 10,000 kCal)
Ans	Aggregate Energy Use= (40000 x 0.92 x 10000) + (360000 x 3450) + (7, 00,000 x 860) + (10,000x 0.885 x 10,500). $MTOE = \frac{(36.8 \times 10^7) + (124.2 \times 10^7) + (60.2 \times 10^7) + (9.2925 \times 10^7)}{10^7}$ = 230.5 Metric Tonnes of Oil Equivalent per month Energy consumption of the textile plant = 230.5 x 12 = 2766 MTOE
S-6	For installing a recuperator in a furnace, the plant has assessed the following time estimates Optimistic Time : 2.5 weeks Most Likely Time : 3 weeks

	<p>Pessimistic Time : 3.5 weeks</p> <p>Find out the “Expected Time”, “Standard Deviation” and “Variance” to complete the activity</p>													
Ans	<p>Expected time = (Optimistic Time + 4 X Most Likely Time + Pessimistic Time)/ 6 = (2.5 + 4 x 3 + 3.5)/ 6 = 3</p> <p>Standard Deviation = (3.5-2.5)/6 = 1/6 = 0.167 Variance = {(PT-OT/6)}² = 1 / 36 = 0.0278</p>													
S-7	<p>A paint drier requires 75.4 m³/min of air at 93°C, which is heated in a steam-coil unit. How many kg of steam at 4 bar does this unit require per hour ? The density of air is 1.2 kg/m³ and specific heat of air is 0.24 kcal/kg°C. The ambient temperature is 32°C.</p> <table border="1" style="margin: 10px auto;"> <thead> <tr> <th rowspan="2">Pressure, bar</th> <th rowspan="2">Temperature, °C</th> <th colspan="3">Enthalpy, kCal/kg</th> </tr> <tr> <th>Water</th> <th>Evaporation</th> <th>Steam</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>143</td> <td>143</td> <td>510</td> <td>653</td> </tr> </tbody> </table>	Pressure, bar	Temperature, °C	Enthalpy, kCal/kg			Water	Evaporation	Steam	4	143	143	510	653
Pressure, bar	Temperature, °C			Enthalpy, kCal/kg										
		Water	Evaporation	Steam										
4	143	143	510	653										
Ans	<p>Solution:</p> <p>Air flow rate = 75.4 m³/min * 60 = 4524 m³/hr Air flow rate = 4524 * 1.2 = 5428.8 kg/hr</p> <p>Sensible heat of air = m * Cp * DT = 5428.8 * 0.24 * (93-32) = 79477.6 kcal/hr</p> <p>Latent heat of Steam = 510 Kcal/kg Steam required = 79477.6 / 510 Steam required = 156 kg/hr</p>													
S-8	<p>An ESCO company is required to invest in a waste heat recovery project, which is expected to yield an annual saving of Rs.10,00,000 and the life of the equipment is 7 years. If the ESCO expects 30 % IRR on this project, calculate the investment required to be made.</p>													
Ans	<p>The PV of the Annual Savings of Rs.1,000,000 per year:</p> $0 = -\frac{\text{Investment}}{(1+0.3)^0} + \frac{1000000}{(1+0.3)^1} + \frac{1000000}{(1+0.3)^2} + \frac{1000000}{(1+0.3)^3} + \frac{1000000}{(1+0.3)^4} + \frac{1000000}{(1+0.3)^5} + \frac{1000000}{(1+0.3)^6} + \frac{1000000}{(1+0.3)^7}$ <p>or</p> <p>Investment = Rs.1,000,000/year (P/AIN Factor) = Rs.1,000,000/year (2.8021) = Rs. 2,802,100</p>													

Thus, we can pay Rs.2,802,100 for the Waste Heat Exchanger and still have a positive NPV.

..... **End of Section II**

Section – III: LONG DESCRIPTIVE QUESTIONS Marks: 6 x 10 = 60

- (i) Answer all **Six** questions
(ii) Each question carries **Ten** marks

L-1	In a Chlor-Alkali plant, an evaporator was designed to concentrate 500 kg of liquor containing solids of 7 % w/w (weight by weight) to 45 % solids w/w in the output. Presently the output from evaporator has 30 % solids w/w. The energy manager suggested overhauling the evaporator to achieve the design rate of solids w/w in the output. Calculate the percentage improvement in water removal in the evaporator after overhauling of the evaporator.
Ans	<p>Amount of feed (input) to the evaporator = 500 Kg Concentration of solids in feed = 7 wt% Amount of solids in feed (input) = $500 * 7 / 100$ = 35 Kg</p> <p><u>Present scenario:</u> Concentration of solids in product (output) = 30 wt% = 0.3</p> <p><u>Mass balance across the evaporator :</u> Amount of product (output) from the evaporator = $35 / 0.3$ = 116.7 Kg</p> <p>Water vapour removed from the evaporator is = $500 - 116.7$ = 383.3 Kg</p> <p><u>Design scenario :</u> Concentration of solids in product (output) = 45 wt% = 0.45</p> <p><u>Mass balance across the evaporator :</u> Amount of product (output) from the evaporator = $35 / 0.45$ = 77.8 Kg</p> <p>Water vapour removed from the evaporator is = $500 - 77.8$ = 422.2 Kg</p> <p>Incremental water removal achieved is = $422.2 - 383.3$ = 38.9 Kg</p> <p>% increase in water removal = $38.9 / 383.3 * 100$ % improvement in water removal after overhaul = 10.14 %</p>

L-2


A process plant is planning to implement a waste heat recovery project. The various activities from procurement to commissioning are given in the table below along with their duration and dependency.

Activity	Predecessor	Time in Week
A	-	3
B	-	5
C	A	4
D	A	6
E	C	5
F	C	3
G	B & D	2
H	D & E	1
I	F,G,H	2

- a) Construct a PERT/CPM network diagram for the above project. **(5 Marks)**
- b) Compute the earliest start, earliest finish, latest start, latest finish and slack for all the activities **(3 Marks)**
- c) Compute the project duration. **(1 Mark)**
- d) Identify the critical activities and the critical path(s). **(1 Mark)**

Ans

a) PERT/CPM network diagram for a project



b) Early start (ES), Early Finish (EF), Latest start (LS), Latest finish (LF) and slack for all the activities. **(3 Marks)**

Activity	Duration	ES	EF	LS	LF	Slack (LS-ES) or (LF-EF)
A	3	0	3	0	3	0
B	5	0	5	6	11	6
C	4	3	7	3	7	0
D	6	3	9	5	11	2
E	5	7	12	7	12	0
F	3	7	10	10	13	3
G	2	9	11	11	13	2
H	1	12	13	12	13	0
I	2	13	15	13	15	0

X1 and X2 are dummy activities

- c) Critical Path: A- C- E- H- I
 d) Total time on critical path (project duration):15 weeks

- L-3 a) Explain briefly three types of Performance Contracting ? (6 Marks)
 b) What are the drawbacks of ESCO? (4 Marks)

Ans Refer BEE Guide Book 1- Page No.178

L-4 A medium size chemical plant receives electricity from grid and also generates electricity from coal based Captive Power Plant (CPP). Coal is also used for process requirements. The fine coal from CPP is sold to neighboring plant. The annual energy details are given below:

Electricity purchased from grid	5 MU
Electricity exported to grid	11 MU

	Power generation from CPP	36 MU						
	Power Supplied from CPP to Process plant	25 MU						
	Fine coal sold to neighboring unit	1000 ton						
	Coal used for process plant	5000 ton						
	GCV of coal	4500 kcal/kg						
	Heat rate of CPP	3500 kcal/kWh						
	Annual Operating Hours	7200						
	Calculate the following:							
	a) Energy usage in toe (tons of oil equivalent)	(5 Marks)						
	b) Coal used in CPP	(3 Marks)						
	c) Calculate the CPP operating power in MW	(2 Marks)						
Ans	<p>Energy usage in TOE (Tons of oil equivalent)</p> <ul style="list-style-type: none"> ➤ Grid electricity Imported = $(5 \times 10^6 \text{kWh}) \times (860 \text{ kcal/kWh}) = (+) 43 \times 10^8 \text{ kcals/year}$ ➤ Power generated from CPP = $(36 \times 10^6 \text{kWh}) \times (3500 \text{ kcal/kWh}) = (+) 1260 \times 10^8 \text{ kcals/year}$ ➤ Coal imported for process = $(5000 \times 10^3 \text{kg}) \times (4500 \text{ kcal/kg}) = (+) 225 \times 10^8 \text{ kcals/year}$ ➤ Power exported to grid = $(11 \times 10^6 \text{kWh}) \times (3500 \text{ kcal/kWh}) = (-) 385 \times 10^8 \text{ kcals/year}$ ➤ Coal fines exported to neighbour = $(1000 \times 10^3 \text{kg}) \times (4500 \text{ kcal/kg}) = (-) 45 \times 10^8 \text{ kcals/year}$ ➤ Net annual energy consumption = $(43+1260+225)-(385+45) = (+) 1098 \times 10^8 \text{ kcals/year}$ <p>a. Energy usage in TOE = $(1098 \times 10^8 \text{ kcals/year}) / (10^7) = 10980 \text{ MTOE}$ (1 MTOE = 10^7 kcals)</p> <p>b. Coal used in CPP = $((36 \times 10^6 \text{ kWh}) \times (3500 \text{ kcal/kWh})) / (4500 \text{ kcal/kg})$ = $28 \times 10^6 \text{ kgs Coal/ Year}$ = $(28 \times 10^6) / 10^3 = 28000 \text{ Tons Coal/ Year}$</p> <p>c. Calculate the CPP operating MW = $(36 \times 10^6 \text{ kWh/year}) / (7200 \text{ hrs/year})$ = 5000 kW = 5 MW</p>							
L-5	<p>a) Write down the steps for computing energy saving using CUSUM over a period. (4Marks)</p> <p>b) Develop a table using a CUSUM technique to calculate energy savings for 8 months period for a production level of 2000 MT per month. Refer to field data given in the table below. (6 marks)</p> <table border="1" style="width: 100%; text-align: center;"> <thead> <tr> <th>Month</th> <th>Actual SEC kWh/MT</th> <th>Predicted SEC kWh/MT</th> </tr> </thead> <tbody> <tr> <td>May</td> <td>1225</td> <td>1250</td> </tr> </tbody> </table>		Month	Actual SEC kWh/MT	Predicted SEC kWh/MT	May	1225	1250
Month	Actual SEC kWh/MT	Predicted SEC kWh/MT						
May	1225	1250						

	June	1227	1250	
	July	1240	1250	
	Aug	1245	1250	
	Sep	1238	1250	
	Oct	1257	1250	
	Nov	1248	1250	
	Dec	1264	1250	
Ans	<p>a) Steps for CUSUM analysis: Refer BEE Guide Book 1 Page No. 229</p> <p>b) Estimate the savings accumulated from use of the heat recovery system.</p>			
	Month	Actual SEC kWh/MT	Predicted SEC kWh/MT	Difference (Actual SEC - Predicted SEC) kWh/MT
	May	1225	1250	-25
	June	1227	1250	-23
	July	1240	1250	-10
	Aug	1245	1250	-5
	Sep	1238	1250	-12
	Oct	1257	1250	+7
	Nov	1248	1250	-2
	Dec	1264	1250	+14
	<p>Positive savings i.e. savings in energy consumption over a period of eight months are</p> <p>56 x 2000 = 112,000 kWh</p>			
L-6	Describe the stages of Gasification of Biomass process with a pictorial diagram and reaction equations ?			
Ans	Refer BEE Guide Book 1- Page No 275-276			

..... **End of Section III**

